

2

[ESM444] The heat energy that is absorbed in the closed system is transferred to the recirculating water of an _____ recirculating system
open

[ESM444] Closed recirculation water system is used to control temperature in _____ .
industry

[ESM444] _____ cooling systems, make-up water is used to maintain a specific temperature or range of temperature for the cooling.
additive

[ESM444] The most reliable corrosion inhibitors for _____ water systems are salts of chromate, molybdate and nitrite materials.
closed

[ESM444] _____ water is needed when leakage has occurred at pump packings
makeup

[ESM444] In boiler furnace, chemical energy in the fuel is converted into _____ .
heat

[ESM444] In industries, _____ is used as a means of transferring heat energy
steam

[ESM444] Maximum effective inhibition is achieved when pH of the systems is maintained between _____
7.5 and 9.5.

[ESM444] The heat is transferred through _____, conduction and convection.
radiation

Whatsapp: 08089722160 or click here for TMA assistance

Practice E-exams & Chat with course mates on noungeeks.net